



Approval of the Trademark Trevira CS®

FiDiVi Tessitura Vergnano S.P.A. Regione Masio, N. 19/BIS 10046 Poirino (TO) Italy

 Application No.:
 181504.1

 Date of issue:
 18.12.2018

 Valid until:
 28.11.2023

Article name: KING L ELAST
End use: Curtains, white
Curtains, coloured

Flat woven fabrics

Velours

Ceiling elements

Wall coverings, sound-absorbing

Square weight (g/m²): 26

According to customer specification

Composition of fabric: Polyester 100%

The tested article KING L ELAST with application no. 181504.1 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

This article also meets the requirements for class I according to the North American standard NFPA 260 for upholstered furniture (based on the Test Reports no. 10-002-775 A + B dated 24.11.2010).

Thus meets also the requirements according to British Standard BS 5852 ignition source 0 (cigarette), ignition source 1 (match) and ignition source (crib 5) in conjunction with suitable combustion modified foams (at least 50 kg/m³). Thus meets the classification according to BS 7176 "Medium Hazard".

This article meets the requirements according to EN 1021 part 1+2 in conjunction with polyurethan foams with a density of more than 30 kg/m³.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements according to ÖNORM B 3825 in conjunction with suitable combustion modified foams.

Trevira GmbH

(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany E-Mail: trademark.service@trevira.com